

PITTSGROVE TOWNSHIP SCHOOLS

Administration Building
1076 Almond Road, Pittsgrove, New Jersey 08318-3950
(856) 358-3094 Fax: (856) 358-6020

STEFANIE FOX-MANNO
Chief Academic Officer, Ext. 4013

MATTHEW C. CAREY
Superintendent of Schools, Ext. 4016

DARREN HARRIS
Bus. Admin./Board Secretary, Ext. 4018



P.R.I.D.E.

September 24, 2021

Dear Parents and Staff:

The Pittsgrove School District is highly committed to the safety of our students and staff. In compliance with New Jersey Department of Education regulations, lead in water testing for drinking water locations throughout the school was performed on August 18-20, 2021. The purpose of the sampling was to identify and address any drinking water location above the EPA action level of 15.5 parts per billion (ppb). A drinking water location is an outlet that is designed or expected to be used for water consumption. These included, but were not limited to, classroom water fountains and sinks, water coolers, sinks in nurse's offices, faculty break rooms, and locations in kitchens used for food preparation. Bathroom, custodial, art room, and science room sinks were not sampled, as these are not expected, nor designed to be used for, water consumption.

Water was allowed to stay motionless in each facility for a minimum of eight hours prior to sampling. After this time of inactivity, an "initial draw" sample was collected from the first water to come out of the outlet. After this sample was collected, water was allowed to flush for the required amount of time, and a second "flush" sample was collected. The purpose of the flush sample is to help determine if contamination does exist, whether it is originating from the outlet itself or from the building's plumbing.

In accordance with the Department of Education regulations, the Pittsgrove Township School District will implement immediate remedial measures for any drinking water outlet with a result greater than the action level of 15 ug/l (parts per billion [ppb]). This includes turning off the outlet unless it is determined the location must on for non-drinking purposes. In these cases, a "DO NOT DRINK – SAFE FOR HANDWASHING ONLY" sign will be posted.

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a plumbing profile for each of the school buildings within Pittsgrove Township School District. Of the 116 samples taken, all by 9 tested below the lead action level established by the US Environmental Protection Agency for lead in drinking water. All water bottle filling stations located in the school are filtered and tested under the action level threshold. A summary of each location above the action level, as well as the short-term response, is found below.

Olivet Elementary School

SAMPLE LOCATION	FIRST DRAW RESULT	FLUSH SAMPLE RESULT	SHORT TERM RESPONSE
Water Cooler – Main Office	18.5 ppb	n/a	Taken out of service

Pittsgrove Middle School

PITTSBORO TOWNSHIP SCHOOLS

Administration Building
1076 Almond Road, Pittsgrove, New Jersey 08318-3950
(856) 358-3094 Fax: (856) 358-6020

STEFANIE FOX-MANNO
Chief Academic Officer, Ext. 4013

MATTHEW C. CAREY
Superintendent of Schools, Ext. 4016

DARREN HARRIS
Bus. Admin./Board Secretary, Ext. 4018



P.R.I.D.E.

SAMPLE LOCATION	FIRST DRAW RESULT	FLUSH SAMPLE RESULT	SHORT TERM RESPONSE
Sink – Room 606	37.3 ppb	2.19 ppb	Posted Signage “DO NOT DRINK – SAFE FOR HANDWASHING USE ONLY”
Sink – Nurse’s Exam Room	30.3 ppb	1.90 ppb	Posted Signage “DO NOT DRINK – SAFE FOR HANDWASHING USE ONLY”
Water Cooler – Hall Left by Rm 506	71.0 ppb	n/a	Taken out of service
Sink – Library AV Room	37.3 ppb	2.19 ppb	Posted Signage “DO NOT DRINK – SAFE FOR HANDWASHING USE ONLY”
Sink – Stage	27.8 ppb	3.05 ppb	Posted Signage “DO NOT DRINK – SAFE FOR HANDWASHING USE ONLY”
Sink – Room 107	39.9 ppb	21.5 ppb	Posted Signage “DO NOT DRINK – SAFE FOR HANDWASHING USE ONLY”
Sink – Room 105	81.2 ppb	3.54 ppb	Posted Signage “DO NOT DRINK – SAFE FOR HANDWASHING USE ONLY”

Schalick High School

SAMPLE LOCATION	FIRST DRAW RESULT	FLUSH SAMPLE RESULT	SHORT TERM RESPONSE
Kettle Filler - Kitchen	95.2 ppb	<1.00 ppb	Taken out of service

Any location requiring corrective actions will be tested prior to being placed back into service.

Health Effects of Lead

High levels of lead in drinking water can cause health problems. Lead is most dangerous for pregnant women, infants, and children under 6 years of age. It can cause damage to the brain and kidneys, and can interfere with the production of red blood cells that carry oxygen to all parts of your body. Exposure to high levels of lead during pregnancy contributes to low birth weight and developmental delays in infants. In young children, lead exposure can lower IQ levels, affect hearing, reduce attention span, and hurt school performance. At very high levels, lead can even cause brain damage. Adults with kidney problems and high blood pressure can be affected by low levels of lead more than healthy adults.

How Lead Enters our Water

PITTSGROVE TOWNSHIP SCHOOLS

Administration Building
1076 Almond Road, Pittsgrove, New Jersey 08318-3950
(856) 358-3094 Fax: (856) 358-6020

STEFANIE FOX-MANNO
Chief Academic Officer, Ext. 4013

MATTHEW C. CAREY
Superintendent of Schools, Ext. 4016

DARREN HARRIS
Bus. Admin./Board Secretary, Ext. 4018



P.R.I.D.E.

Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like groundwater, rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and in building plumbing. These materials include lead-based solder used to join copper pipe, brass, and chrome-plated brass faucets. In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials. However, even the lead in plumbing materials meeting these new requirements is subject to corrosion. When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into the drinking water. This means the first water drawn from the tap in the morning *may* contain fairly high levels of lead.

Lead in Drinking Water

Lead in drinking water, although rarely the sole cause of lead poisoning can significantly increase a person's total lead exposure, particularly the exposure of children under the age of 6. EPA estimates that drinking water can make up 20% or more of a person's total exposure to lead.

For More Information

A copy of the test results is available in our central office for inspection by the public, including students, teachers, other school personnel, and parents, and can be viewed between the hours of 8:00 a.m. and 4:00 p.m. and are also available on our website at www.pittsgrove.net.

For more information on reducing lead exposure around your home and the health effects of lead, visit EPA's Web site at www.epa.gov/lead, call the National Lead Information Center at 800-424-LEAD, or contact your health care provider.

If you are concerned about lead exposure at this facility or in your home, you may want to ask your health care providers about testing children to determine levels of lead in their blood.

Sincerely,

Matthew C. Carey
Superintendent of Schools